

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

PV 50669326 0001

Berichtsnummer Report No.:

CN25Q4ZB 001

Genehmigungsinhaber License Holder:

MUNDRA SOLAR ENERGY LIMITED
Adani Corporate House, Shantigram
Near Vaishno Devi Circle
S. G. Highway, Khodiyar
AHMEDABAD 382421
India

Fertigungsstätte Manufacturing Site:

2 Fertigungsstätten auf Folgeseiten
Listing of 2 factories on following pages

Prüfzeichen Test Mark:

Geprüft nach Tested according to:

IEC 61701:2020
EN IEC 61701:2020

Geräteidentifikation
Product Identification
Produkt: PV Module

Product:
Modell: Modelle sind auf nächste(r) Seite(n) gelistet

Type: *Type designation(s) are listed on the next page(s)*
Technische Daten: Class II acc. to IEC 61140

Technical Data: For other ratings, refer to the test report

Gültig bis: 2027-06-13

Date of expiry:
Gültig ab: 2025-03-20

Valid from:
Ausstellungsdatum: 2025-03-20

Date of issue:
Zertifizierungsstelle:
Certification body:

Weichun Li



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

www.tuv.com

 **TÜVRheinland®**
Precisely Right.

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

PV 50669326 0001

Berichtsnummer *Report No.:*

CN25Q4ZB 001

Produkt *Product:* PV Module

Modell *Type:*

Bezeichnung *Designation:*

Max. System Voltage: up to 1500 VDC (Voc at STC):

Monofacial PV module with 144 mono bifacial cut cells:

ASM-M10-144-xxx (xxx=520-550 in steps of 1, 144 cells)

Bifacial PV module with 144 mono bifacial cut cells:

ASB-M10-144-xxx (xxx=520-590, in steps of 1, 144 cells)

Bifacial PV module with 132 mono bifacial cut cells:

AB-G12R-132-xxx (xxx=590-620, in steps of 1, 132 cells)

xxx represents output power at STC in Wp

Remarks:

Valid in conjunction with TÜV Rheinland certificate
acc. IEC 61730 and only for the material combination
as listed in above written test report.

Test performed with test method 6 acc. to IEC 60068-2-52.

Conditions:

The product test is voluntarily according to technical
regulations. Any change of the design, materials, components
or processing may require the repetition of some of the
qualification tests in order to retain type approval.
Accordingly the repetition of the tests that are basis of
this certificate may be required.

Validity: 13 June 2027



Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

PV 50669326 0001

Berichtsnummer *Report No.:*

CN25Q4ZB 001

Produkt *Product:*

PV Module

Fertigungsstätten *Factories:*

-
- 1 MUNDRA SOLAR ENERGY LIMITED
Survey No 180 P, C/O Mundra Solar
Technopark Pvt Ltd, EMC, Village: Vandh
& Tunda, Mundra, Kutch, APSEZ, Kachchh,
Gujarat, 370435
India
 - 2 MUNDRA SOLAR PV LIMITED
Survey No 180 P, C/O Mundra Solar
Technopark Pvt Ltd, EMC, Village: Vandh
& Tunda, Mundra, Kutch, APSEZ, Kachchh,
Gujarat, 370435
India

