

Certificate



Certificate no.

TU 722240014 01

License Holder:

Mundra Solar Energy Limited
Adani Corporate House,
Shantigram, Near Vaishno Devi Circle,
S. G. Highway, Khodiyar,
Ahmedabad, Gujarat – 382421, India

Manufacturing Plant(s):

Refer to the latest revision of Appendix 2,
List of Factories.

Test report no.: USA- 322440011.001

Client Reference: Mr. Rishabh Malviya

Tested to: UL 61215-1:2017, UL 61215-1-1:2017, UL 61215-2:2017,
UL 61730-1:2017, UL 61730-2:2017

Certified Product: Photovoltaic (PV) Modules

Model Designations:

Monofacial PV module with glass front cover and polymeric white back cover

ASM-M10-144-xxx (xxx = 530–540 in steps of 1, with 144 bifacial cut cells)
xxx represents output power in Wp.

Maximum System Voltage: 1500 V DC

Safety Class: Class II

Max Overcurrent Protection Rating: 25 A

Fire Classification Type: Type 7

Electrical ratings are provided at Standard Test Conditions (STC) of
1000 W/m², AM 1.5 spectrum, 25°C cell temperature.

Appendices: 1, 1-6 2, 1

Licensed Test Mark:



Date of Issue:

20 May 2022