

# Certificate



Certificate no.

TU 722240014 02

**License Holder:**

Mundra Solar Energy Limited  
Adani Corporate House,  
Shantigram, Near Vaishno Devi Circle,  
S. G. Highway, Khodiyar,  
Ahmedabad, Gujarat – 382421, India

**Manufacturing Plant(s):**

Refer to the latest revision of Appendix 2,  
List of Factories.

**Test report no.:** USA- 322440011.002

**Client Reference:** Mr. Rishabh Malviya

**Tested to:** UL 61215-1:2017, UL 61215-1-1:2017, UL 61215-2:2017,  
UL 61730-1:2017, UL 61730-2:2017

**Certified Product:** Photovoltaic (PV) Modules

Model Designations:

Bifacial PV module with glass front cover and glass back cover

ASB-M10-144-xxx (xxx = 530 – 540 in steps of 1, 144 bifacial cut cells)  
xxx represents output power in Wp.

Maximum System Voltage: 1500 V DC

Safety Class: Class II

Max Overcurrent Protection Rating: 25 A

Fire Classification Type: Type 19

Electrical ratings are provided at Standard Test Conditions (STC) of  
1000 W/m<sup>2</sup>, AM 1.5 spectrum, 25°C cell temperature.

Appendices: 1, 1-7 2, 1

**Licensed Test Mark:**



**Date of Issue:**

20 May 2022